

Deptford Township Municipal Utilities Authority

PUBLIC WATER SYSTEMS ID# 0802001

2016 ANNUAL WATER QUALITY REPORT

JUNE 2017



PO Box 5506 • Deptford, NJ 08096
Tel: 856-415-1111 Fax: 856-415-0199

PROTECTING YOUR DRINKING WATER

To comply with state and federal regulations, the Deptford Township Municipal Utilities Authority [DTMUA] issues a report annually describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and your awareness of the need to protect our drinking water sources.

Drinking water standards are regulations that the Environmental Protection Agency (EPA) sets to control the level of contaminants in the nation's drinking water. These standards are part of the Safe Drinking Water Act's (SDWA) "multiple barrier" approach to drinking water protection, which includes assessing and protecting drinking water sources; protecting wells and collection systems; making sure water is treated by qualified operators; ensuring integrity of distribution systems; and making information available to the public on the quality of their drinking water.

THE ORIGIN OF YOUR WATER

The source of Deptford Township Municipal Utilities Authority [DTMUA] is groundwater from seven wells, each with individual chlorinating treatment facilities. The wells vary in depth from 261 to 355 feet deep. Water pumped from the wells is treated with a polyphosphate for corrosion control and to minimize the staining effects on fixtures. The seven wells pump water from the Potomac-Raritan-Magothy (PRM) Aquifer formation. The DTMUA's annual diversion from the Aquifer for the year 2016 was 353.870 million gallons.

Deptford Township used 939,470,000 gallons of water last year. In order to meet this demand, the DTMUA must augment its well water supply with the bulk purchase of treated water from NJ American Water Company (NJAWC). NJAWC's water originates from the Delaware River. Approximately sixty-two percent of our water came from NJAWC in 2016.

The DTMUA has approximately 11,079 water connections serving over 30,569 residents (estimate provided by the U.S. census bureau, 2015). Last year, the DTMUA supplied on average, 2.12 million gallons of water per day during the winter months and 3.03 million gallons of water per day during the summer months. This equates to approximately 84 gallons of water daily per person in the service area.

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for DTMUA's water system which is available at www.state.nj.us/dep/swap or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550.

All seven wells tested low in the susceptibility ratings for pathogens, nutrients, pesticides, volatile organic compounds and radon. All seven wells tested medium for disinfection by-product precursors and inorganics. Four wells tested medium and three wells tested low for radionuclides.

OUR COMMITMENT TO YOU

The DTMUA is committed to providing residents with a safe and reliable supply of high-quality drinking water all year round. Each day our employees are working to ensure that the water delivered from our facilities meet or exceed all Federal and State regulatory requirements.

This brochure is a summary of the quality of water provided to our customers last year. Included are details about where your water comes from, what our test results show about it, and how it compares to standards set forth by the Federal and State regulatory agencies. Copies of all test results as submitted to regulatory agencies are available for examination during normal business hours at the DTMUA's office.

WAIVER

The SDWA regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals, and synthetic organic chemicals. Our system received monitoring waivers for asbestos and synthetic organic chemicals.

The State of New Jersey allows monitoring for some substances less than once a year because the concentrations of these substances do not change frequently. Some of our data in the Table of Detected Contaminants, though representative, may be more than one year old.

TABLE OF DETECTED CONTAMINANTS - RESULTS FOR 2016

Contaminants	Unit	MCL	MCLG	Deptford MUA Highest Detection	Deptford MUA Range Detected	NJAWC Highest Detection	NJAWC Range Detected	Major Sources	
TREATMENT BYPRODUCTS, TREATMENT BYPRODUCTS PRECURSOR REMOVAL AND TURBIDITY									
Ratio of Actual /Required TOC Removal	Ratio	TT: Running Annual Average \geq 1.0	NA	-	-	1.81	1.27 to 1.81	Naturally present in the environment	
Total Organic Carbon ⁽¹⁾	%	TT \geq 35% Removal	NA	-	-	44% ⁽³⁾	44% to 63%	Naturally present in the environment	
Turbidity ⁽¹⁾⁽⁴⁾	NTU	TT=1 NTU	1	-	-	0.16	0.04 to 0.16	Soil runoff	
	%	TT=% of samples $<$ 0.3 NTU	0	-	-	100%	NA	Soil runoff	
RADIOLOGICALS									
Alpha Emitters	pCi/l	15	0	-	-	NA	NA	Erosion of natural deposits	
Combined Radium (Ra226/228) 2014	pCi/l	5	0	1.01	0.97 to 1.01	NA	NA	Erosion of natural deposits	
INORGANIC SUBSTANCES									
Barium (2014) ⁽⁶⁾	ppm	2	2	0.88	0.02 to 0.88	NA	NA	Discharge of drilling wastes & metal refineries; Erosion of natural deposits	
Copper (2013 - 2014) ⁽⁷⁾	ppm	AL=1.3	AL=1.3	0.429 with 0 sites exceeding AL	Homes above AL[0]	0.03	Home above AL[0]	Corrosion of household plumbing systems	
Fluoride(not added) (2014) ⁽⁷⁾	ppm	4	4	1.25	0.109 to 1.25	NA	NA	Erosion of natural deposits; Discharge from fertilizer and aluminum factories	
Lead (2013 - 2014) ⁽⁷⁾	ppb	AL=15	AL=0	58.2 with 1 site exceeding AL	Homes above AL[1]	-	-	Corrosion of household plumbing systems	
Nickel (2014) ⁽⁷⁾	ppb	100	100	3	0.15 to 3	NA	NA	Erosion of natural deposits	
Nitrate	ppm	10	10	0.829	ND to 0.829	1	ND to 1	Runoff from fertilizer use; industrial or domestic wastewater discharges; erosion of natural deposits	
Sodium	ppm	50	50	57.4	18.5 to 57.4	NA	NA	Erosion of natural deposits	
DISINFECTION BY-PRODUCTS					LRAA				
Stage 2 Total Trihalomethanes (TTHM)	ppb	80	NA	27.9	NA	.02 to 27.9	NA	NA	Drinking water disinfection
Stage 2 Total Halacetic Acid (HAA5)	ppb	60	NA	5.98	NA	$<$ 2.0 to 5.98	NA	NA	Drinking water disinfection
MICROBIAL CONTAMINANTS									
Total Cloriform Bacteria	Positive Monthly Samples	5%	0	0	0	NA	NA	Naturally present in environment	
DISINFECTANTS									
Chlorine	ppm	MRDL = 4	MRDLG = 4	0.5	0.2 - 0.5	1.02 ⁽⁵⁾	0.36 to 1.02	Water additives to control microbes	

FOOTNOTES

- DTMUA was not required to test for these substances.
- This level represents the highest annual quarterly average calculated from the data collected. Compliance is based on running annual average.
- Data represents the lowest removal of Total Organic Carbon (TOC).
- 100% of the turbidity readings were below the treatment technique requirement of 0.3 NTU. Turbidity is a measure of the cloudiness of the water, and a good indicator of the effectiveness of our filtration.
- Data represents the lowest and highest chlorine residual entering the distribution system from our surface water treatment plant.
- Data represents highest locational quarterly running annual average.
- The State of New Jersey allows us to monitor for certain contaminants less than once a year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative, are more than one year old.

TABLE OF DETECTED CONTAMINANTS - RESULTS FOR 2016

UNREGULATED CONTAMINANTS MONITORING (UCMR3): 2014 - 2015 DTMUA Results

Parameter	Units	Highest Local Average	Range Detected	Typical Source
1,1-Dichloroethane	ppb	< 0.03	0 to <0.03	Halogenated alkane; used as a solvent
1, 2, 3 - Trichloropropane*	ppb	< 0.03	0 to <0.03	Halogenated alkane; used as ingredient in paint, varnish remover, solvents and degreasing agents
*1, 2, 3 - Trichloropropane was detected in purchased water previously used to supply a limited number of customers. This purchased supply was discontinued in 2015. 1, 2, 3 - Trichloropropane was not detected in any of New Jersey America Water's sources.				
1,4-Dioxane	ppb	.1	<0.07 to 1	Cyclic aliphatic ether; used as a solvent or solvent stabilizer in manufacture and processing of paper, cotton, textile products, automotive coolant, cosmetics and shampoos
Bromochloromethane	ppb	< 0.06	0 to < 0.06	Used as a fire-extinguishing fluid, and explosive suppressant, and as a solvent in the manufacturing of pesticides
Chlorate	ppb	300.1	0 to 300.1	Agricultural defoliant or desiccant; disinfection byproduct; and used in production of chlorine dioxide
Chromium (VI)	ppb	1.5	.03 to 1.5	Naturally-occurring element; used in making steel and other alloys; chromium -3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation
Cobalt	ppb	< 1	0 to < 1	Naturally-occurring element found in the earth's crust and at low concentrations in sea water, and in some surface and ground water; cobaltous chloride was formerly used in medicine as a germicide
Molybdenum	ppb	2.2	<1 to 2.2	Naturally-occurring element found in ores and present in plants, animals and bacteria; commonly used form molybdenum trioxide used as a chemical reagent
Strontium	ppb	640	92 to 640	Naturally-occurring element; historically commercial use of strontium has been in faceplate glass of cathode-ray tube televisions to block x-ray emissions
Vanadium	ppb	<.02	0 to <.02	Naturally-occurring elemental metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst

UNREGULATED CONTAMINANTS MONITORING (UCMR3): 2013 - 2014 NJWC Results

Parameter	Units	Highest Locational Average	Range Detected	Typical Source
Hexavalent Chromium	ppb	1.0	0.65 to 1.22	Naturally-occurring element; used in making steel and other alloys; chromium -3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation
Total Chromium	ppb	1.3	0.8 to 1.8	Naturally-occurring element; used in making steel and other alloys; chromium -3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation
Molybdenum	ppb	1.4	1.2 to 1.7	Naturally-occurring element found in ores and present in plants, animals and bacteria; commonly used form molybdenum trioxide used as a chemical reagent
Strontium	ppb	79	74.3 to 90.2	Naturally-occurring element; historically commercial use of strontium has been in faceplate glass of cathode-ray tube televisions to block x-ray emissions

TABLE DEFINITIONS

90th percentile Value: Of the samples taken, 90% of the values of the results were below the level indicated in the table.

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA - Not Applicable

ND - Not Detected

NJAWC - New Jersey American Water Company.

NR (Not Regulated): Indicates that there currently are no available regulations for these substances.

NTU (Nephelometric Turbidity Units): Measurement of clarity, or turbidity of water.

ppm (parts per million): One part substance per million parts water.

ppb (parts per billion): One part substance per billion parts water.

pCi/L (picoCuries per liter): A measure of the radioactivity in water.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

SECONDARY STANDARDS (RELATED TO THE AESTHETIC QUALITY OF DRINKING WATER)

Substance	Unit	Recommended Upper Limit Detection	DTMUA Highest Detection	DTMUA Range Detected	NJAWC Highest Detection	NJAWC Range Detected	Major Sources
Iron	ppb	300	ND	ND	NA	NA	Not Available
Sodium	ppm	50	57.4	18.5 to 57.4	NA	NA	Naturally occurring
Sulfate (2011)	ppm	250	34.2	6.76 to 34.2	NA	NA	Erosion of natural deposits

Iron: The secondary recommended upper limit for iron is based on unpleasant taste of the water and staining of fixtures and laundry. Iron is an essential nutrient, but some people who drink water with iron levels well above the recommended upper limit could develop deposits of iron in a number of organs of the body.

SPECIAL CONSIDERATIONS REGARDING CHILDREN, PREGNANT WOMEN, NURSING MOTHERS, AND OTHERS

Children may receive a slightly higher amount of a contaminant present in the water than do adults, on a body weight basis, because they may drink a greater amount of water per pound of body weight than do adults. For this reason, reproductive or developmental effects are used for calculating a drinking water standard if these effects occur at lower levels than other health effects of concern. If there is insufficient toxicity information for a chemical (for example, lack of data on reproductive or developmental effects), an extra uncertainty factor may be incorporated into the calculation of the drinking water standard, thus making the standard more stringent, to account for additional uncertainties regarding these effects. In the cases of lead and nitrate, effects on infants and children are the health endpoints upon which the standards are based.

REQUIRED HEALTH LANGUAGE

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the EPA Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Substances that may be present in source water before we treat it include:

- **INORGANIC SUBSTANCES**, such as salts and metals that can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **MICROBIAL SUBSTANCES**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Sodium: For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the secondary RUL may be of concern to individuals on a sodium restricted diet. This shall serve as public notice for consumers that the sodium levels slightly exceed the secondary standards for sodium.

- **ORGANIC CHEMICAL SUBSTANCES**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- **PESTICIDES AND HERBICIDES**, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- **RADIOACTIVE SUBSTANCES**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

NITRATE: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

LEAD : If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. DTMUA is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have water tested. Information on lead in drinking water is available from Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

2017 MEETING DATES

Our monthly meetings are usually held on the 3rd Tuesday of each month at 5:30pm at 898 Cattell Road. Below is a list of meeting dates for 2016.

JUNE 20, 2017	OCTOBER 17, 2017
JULY 18, 2017	NOVEMBER 21, 2017
AUGUST 15, 2017	DECEMBER 19, 2017
SEPTEMBER 19, 2017	JANUARY 16, 2018

SOURCE OF INFORMATION

DEPTFORD TOWNSHIP MUNICIPAL UTILITIES AUTHORITY

898 Cattell Rd., Wenonah, NJ 08096
Tel: (856) 415-1111 Fax: (856) 415-0199
Monday - Friday from 7:45am to 4:45pm
www.deptfordmua.com

NEW JERSEY AMERICAN WATER COMPANY

1025 Laurel Oak Road, Voorhees, NJ 08043
Customer Service - Tel: (800) 272-1325
www.amwater.com

U.S. EPA SAFE DRINKING WATER: (800) 426-4791

NJ DEP BUREAU OF SDW: (609) 292-5550

VULNERABLE POPULATION LANGUAGE

"Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV, AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791."

BOARD MEMBERS

LINDA TRAMO - CHAIRMAN
JUDITH TANGER - VACANT
DANIEL REED - SECRETARY / TREASURER
RUBY LOVE - BOARD MEMBER
JOSEPH SACERDOTE - BOARD MEMBER
JOHN BRESCH - ALTERNATE MEMBER #1
EDWARD KALINOWSKI - ALTERNATE MEMBER #2

PROFESSIONALS & STAFF

ROBERT HATALOVSKY JR. - EXECUTIVE DIRECTOR
SCHROEDER LAW GROUP - ATTORNEY
BACH ASSOCIATES - CONSULTING ENGINEER
BOWMAN AND COMPANY - AUDITOR
MICHAEL J. CUSICK - UTILITIES SUPERINTENDENT

DTMUA PWS ID #: NJ0802001

NJAWC PWS ID#: 0327001